



Village of Davis Junction
106 N. Elm Street, P.O. Box 207
Davis Junction, Illinois 61020
(815) 645-8000
(815) 645-8055 fax

REQUIREMENTS FOR CONSTRUCTION OF SIDEWALK

The following is a guideline of requirements that need to be met along with the completed application in order to apply for a sidewalk permit.

APPLICATION

- Anyone who intends to construct, alter, repair, replace, or rebuild a patio must apply for a permit in accordance with the Village's Code.
- Note that a completed Application must include the PIN (Property Index Number) which is located on your tax bill or available with the Ogle County Treasurer's Office.
- A completed Application must also include two (2) copies of the Plat of Survey indicating location and size of the sidewalk.
- Be sure to check with your Homeowner's Association regarding covenant restrictions, if applicable.
- All applicants and permit holders must contact JULIE, INC @ 1-800-892-0123 two (2) days working prior to digging in order to locate utilities.

CODE REQUIREMENTS

- The concrete thickness must be a minimum of four (4) inches except in driveways other than normal private driveways (i.e. commercial drives, alleys, parking lot entrances). At such places, the concrete must be a minimum of six (6) inches in depth.
- Concrete composition shall comply with the specifications for Class SI concrete.
- Slump: 2-4 inches
- Minimum Compressive Strength: 3,500 PSI after 14 days
- Air Content: 5-8%
- Sidewalk will have the normal cross slope of one-fourth (1/4) inches per foot drop towards the street where applicable.
- Dummy transverse joints shall be placed at five (5) feet intervals and the joints shall be finished with a scoring tool.
- The gravel base thickness must be a minimum of four (4) inches compacted.
- All vegetation must be cleaned away from the area.